



# TOWN OF WINCHESTER

INCORPORATED JULY 2<sup>ND</sup> 1753



1 Richmond Road • Winchester, New Hampshire 03470  
Voice: (603) 239-4951 • Fax: (603) 239-4710 • TDD Access: Relay NH 1-800-735-2964  
selectmen@winchester.nh.gov • www.winchester-nh.gov

These rules are designed to regulate, control and prevent the contamination of public drinking waters by the backflow of water or other liquids, gases, mixtures or substances into the distribution system of a public water system from a source or sources other than its intended source.

Backflow prevention devices, required by the rules and policies of the State and/or by the Water Department shall be of a model and construction approved by the Water Department and by the State of New Hampshire.

The Water Department will ensure that backflow prevention devices are installed where required, test for proper functioning upon completion of installation, and to see that the devices are inspected and tested at least semi annually (or more frequently as required by the Water Department or the State of New Hampshire) to determine that the devices meet applicable standards.

All installations, repairs, testing, overhauls or replacements of backflow devices, whenever they are found defective, will be at the expense of the owner.

Permits will be renewed every five years, whenever a change has occurs in the classification of hazard as determined by the Water Department and/or the State of New Hampshire and/or backflow prevention devices.

Permits shall be non transferable.

OWNER'S NAME: \_\_\_\_\_

DATE OF APPLICATION: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

MAP# \_\_\_\_\_ LOT# \_\_\_\_\_

LOCATION OF BACKFLOW DEVICE:

MAKE: \_\_\_\_\_ MODEL: \_\_\_\_\_ SIZE: \_\_\_\_\_

DESCRIPTION OF CONTAMINATIONS:

OWNER'S SIGNATURE  
(UPON APPROVAL)

SUPERINTENDENT'S SIGNATURE